

# TYPE APPROVAL CERTIFICATE

Certificate No:  
**TAE00002DW**  
Revision No:  
**1**

## This is to certify:

**That the Electric Power Cable**

with type designation(s)  
**LKM-HF, LKM-SHF2, LKMM-HF, LKMM-SHF2, LKAM-HF, LKAM-SHF2**

Issued to  
**Helkama Bica Oy**  
**Kaarina, Finland**

is found to comply with  
**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application :

**Unarmoured Power and control cable.**

**Products approved by this certificate are accepted for installation on all vessels classed by DNV.**

Type	Rated voltage (kV)	Temp. class (°C)
LKM-HF, LKM-SHF2	0,6/1	90
LKMM-HF, LKMM-SHF2	0,6/1	90
LKAM-HF, LKAM-SHF2	0,6/1	90

Issued at **Høvik** on **2023-01-01**

This Certificate is valid until **2027-12-31**.

DNV local unit: **Finland CMC**

Approval Engineer: **Ivar Bull**

for **DNV**



Digitally Signed By: Elter, Frederik Tore  
Location: DNV Høvik, Norway

**Frederik Tore Elter**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Product description

Types: LKM-HF, LKM-SHF2,  
 LKMM-HF, LKMM-SHF2,  
 LKAM-HF, LKAM-SHF2

### Construction:

Conductor: Plain (optional tinned), stranded copper class 2 or class 5  
 Core insulation: XLPE  
 Bedding: Extruded filler (LKMM-)  
 Screen: Polyester coated aluminium with tinned copper drain wire (LKAM-)  
 Sheath: SHF1 or SHF2

### LKM-HF, LKM-SHF2

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1, 2, 3, 4, 5	1 - 300
7	1 - 25
10, 12, 14, 16, 19, 24, 27, 37	1 - 1,5 - 2,5

### LKMM-HF, LKMM-SHF2

No of cores:	Cross sectional area [mm <sup>2</sup> ]
2, 3, 4, 5	1 - 300
7	1 - 25
12, 19, 24, 27, 37	1 - 1,5 - 2,5

### LKAM-HF, LKAM-SHF2

No of cores:	Cross sectional area [mm <sup>2</sup> ]
2, 3, 4, 5, 7, 10, 12, 14, 16, 19, 24, 27, 32, 37	1 - 1,5 - 2,5

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Data sheets: Specifications HBKQ 9.SPEC.3, 38, 28, 104, 106, 112  
 Test reports: Helkama test document LKAM-HF/ATT3X1\_5 dated 1999-03-24  
 Fire test according to IEC 60332-3A dated 1998-11-24  
 FIMKO Report No. 2761 dated 15.12.1998  
 Helkama test document 25782.bak LKAM-HF 3X1,5 dated 2014-02-07  
 Helkama test document LKM-HF/1TT3X1\_5 and LKM-HF/1TT3X70 dated 1999-03-24  
 SP 98R 3404A dated 1998-12-22  
 FIMKO report No. 2759 dated 1998-12-15  
 Fire tests according to IEC 60332-3A dated 1998-11-24  
 Helkama test document 24991.bak LKM-HF 3x35 RT dated 2014-02-07  
 Helkama test documents DnV-TAP1/TT\_MM.XLS dated 2000-02-22 and DnV-TAP2/TT\_MM.XLS dated 2000-03-07.  
 Helkama test document 24991.bak LKM-HF 3x35 RT dated 2014-02-07

## Tests carried out

Standard	Release	General description	Limitation
DNV CP-0399	2021-08	Electric cables.	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	

Standard	Release	General description	Limitation
IEC 60332-1-2	2015-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test Clause 45.1 Methods of determination of low levels of chlorine, and/or Bromine and/or iodine Clause 45.2 Methods of determination of low levels of fluorine	HCl + HBr + HJ max 0,5% [0,014% can be detected]  HF max 0,1% [0,02% can be detected]
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus Part 2: Test procedure and requirements	Low smoke Light transmittance >60%

### Marking of product

HELKAMA - LKM-HF or LKM-SHF2 - size - 0,6/1 kV- IEC 60332-3-22 – Lot no or  
 HELKAMA - LKMM-HF or LKMM-SHF2- size - 0,6/1 kV- IEC 60332-3-22 – Lot no or  
 HELKAMA - LKAM-HF or LKAM-SHF2 - size - 0,6/1 kV- IEC 60332-3-22 – Lot no

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer’s product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years.

A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE